

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0432-24-HI-CAL-10C

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE20CP004	Range	-50 ~ 250
Instrument Description	PULVERIZER B DIFFERENTIAL PRESSURE 3	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501619	Cal. Date	25-05-2024
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature 27.2 °C
Humidity 50 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-50	4.000	4.000	0.000	0.000	Pass						
25	8.000	8.000	0.000	0.000	Pass						
100	12.000	12.001	0.001	0.006	Pass						
175	16.000	16.004	0.004	0.025	Pass						
250	20.000	20.007	0.007	0.044	Pass						
250	20.000	20.007	0.007	0.044	Pass						
175	16.000	16.002	0.002	0.012	Pass						
100	12.000	12.005	0.005	0.031	Pass						
25	8.000	8.002	0.002	0.013	Pass						
-50	4.000	4.003	0.003	0.019	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter


This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved by,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

