

**REPORT OF INSPECTION**  
**MOTORIZED OF VALVE**  
Certificate No. : 0847-24-HI-CAL-10J

**Customer Information**

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

**Instrument Information**

KKS No. 60HFE21AA202 Power Supply 380 VAC  
Instrument Description MILL INLET AIR DAMPER Stroke 180 deg  
Manufacture AUMA Inspection Date 15-05-2024  
Model SA16.2-F16  
Serial Number 2219MD24627  
Instrument Location BOILER 1.5ST FLOOR

**Environment Condition**

Temperature 32.2 °C  
Humidity 43 % RH

**Traveling Time**

Open to Close 43.40 s  
Close to Open 43.40 s

**Stroke Result**

Command	Local	Stroke	DCS FB
[%]	[%]	[deg]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

**Visual Inspection**

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Gearbox Condition  OK  Not OK

**Remark**

**Test Equipment**

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

**Inspection Method**

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page

Date of issue, 16-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

