

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0235-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE21CF001
Instrument Description PULVERIZER A PRIMARY AIR FLOW 1
Manufacture YOKOGAWA
Model / Serial Number EJX130A / 91V501641
Instrument Location BOILER 2ND FLOOR

Range 0 ~ 19.4
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 24-05-2026

Environment Condition

Temperature 24 °C Humidity 60 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
4.900	8.041	8.041	0.000	0.000	Pass						
9.700	12.000	12.001	0.001	0.006	Pass						
14.600	16.041	16.041	0.000	0.000	Pass						
19.400	20.000	19.999	-0.001	-0.006	Pass						
14.600	16.041	16.044	0.003	0.019	Pass						
9.700	12.000	11.997	-0.003	-0.019	Pass						
4.900	8.041	8.028	-0.013	-0.081	Pass						
0.000	4.000	4.001	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☐ Corrosion Check ☐
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	2448033	1748/25/EX/03/2024	24-03-2024
FLUKE PRESURE MODULE 750PD4	4474073	S.25 003 037 / P	05-03-2025

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 26-05-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signature,

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person