

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0224-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE21CF002	Range	0 ~ 19.4
Instrument Description	PULVERIZER A PRIMARY AIR FLOW 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501642	Cal. Date	23-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature: 27.2 °C
 Humidity: 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.000	0.000	0.000	Pass						
4.9	8.000	7.998	-0.002	-0.012	Pass						
9.7	12.000	11.976	-0.024	-0.150	Pass						
14.6	16.000	16.044	0.044	0.275	Pass						
19.4	20.000	20.007	0.007	0.044	Pass						
19.4	20.000	20.007	0.007	0.044	Pass						
14.6	16.000	16.039	0.039	0.244	Pass						
9.7	12.000	12.001	0.001	0.006	Pass						
4.9	8.000	8.001	0.001	0.006	Pass						
0.0	4.000	3.998	-0.002	-0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter


This certificate comprise of 1 page
 Date of issue, 24-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Authorized Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person