

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0237-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE21CF003
Instrument Description PULVERIZER A PRIMARY AIR FLOW 3
Manufacture YOKOGAWA
Model / Serial Number EJX130A / 91V501643
Instrument Location BOILER 2ND FLOOR

Range 0 ~ 19.4
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 24-05-2026

Environment Condition

Temperature 24 °C Humidity 60 % RH

Calibration Result

Data Reading (Transmitter)										
As Found						As Left				
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]
0.000	4.000	3.998	-0.002	-0.013	Pass					
4.900	8.041	8.050	0.009	0.056	Pass					
9.700	12.000	12.006	0.006	0.038	Pass					
14.600	16.041	16.006	-0.035	-0.219	Pass					
19.400	20.000	20.006	0.006	0.038	Pass					
14.600	16.041	16.005	-0.036	-0.225	Pass					
9.700	12.000	12.008	0.008	0.050	Pass					
4.900	8.041	8.046	0.005	0.031	Pass					
0.000	4.000	4.002	0.002	0.013	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☐ Corrosion Check ☐
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	2448033	1748/25/EX/03/2024	24-03-2024
FLUKE PRESURE MODULE 750PD4	4474073	S.25 003 037 / P	05-03-2025

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages

Date of issue, 26-05-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person