

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0226-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE22CF001	Range	0 ~ 19.4
Instrument Description	PULVERIZER B PRIMARY AIR FLOW 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501644	Cal. Date	23-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature 27.1 °C
Humidity 52 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.0	4.000	4.001	0.001	0.006	Pass						
4.9	8.000	8.002	0.002	0.013	Pass						
9.7	12.000	12.000	0.000	0.000	Pass						
14.6	16.000	16.005	0.005	0.031	Pass						
19.4	20.000	20.006	0.006	0.038	Pass						
19.4	20.000	20.006	0.006	0.038	Pass						
14.6	16.000	16.005	0.005	0.031	Pass						
9.7	12.000	12.000	0.000	0.000	Pass						
4.9	8.000	8.002	0.002	0.013	Pass						
0.0	4.000	4.002	0.002	0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 24-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

