

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0230-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFE23CF002	Range	0 ~ 19.4
Instrument Description	PULVERIZER C PRIMARY AIR FLOW 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501648	Cal. Date	21-05-2024
Instrument Location	BOILER 2ND FLOOR		

### Environment Condition

Temperature: 27.2 °C  
Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	4.001	0.001	0.006	Pass						
4.85	8.000	8.002	0.002	0.013	Pass						
9.70	12.000	12.000	0.000	0.000	Pass						
14.55	16.000	16.001	0.001	0.006	Pass						
19.40	20.000	20.003	0.003	0.019	Pass						
19.40	20.000	20.003	0.003	0.019	Pass						
14.55	16.000	16.000	0.000	0.000	Pass						
9.70	12.000	12.001	0.001	0.006	Pass						
4.85	8.000	8.003	0.003	0.019	Pass						
0.00	4.008	4.002	-0.006	-0.038	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 22-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. TINDOYAN

Calibrated by,



Alidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

