

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0699-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HFE24CT001 Range 0 ~ 400  
 Instrument Description PULVERIZER D PRIMARY AIR Unit °C  
 TEMPERATURE 1  
 Manufacture YAMARI Out. Signal 4 - 20 mA  
 Model TM Max. Deviation 4 °C  
 Serial Number 5451726 Cal. Date 10-05-2024  
 Instrument Location BOILER 1ST FLOOR Temp. Element Thermocouple Type E

### Environment Condition

Temperature 49 °C  
 Humidity 54 % RH

### Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.990	40.200	0.210	Pass										
100	100.000	101.400	1.400	Pass										
200	200.000	202.400	2.400	Pass										
300	300.020	303.300	3.280	Pass										
400	400.000	403.700	3.700	Pass										

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 11-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

