

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 0985-24-HI-CAL-10J

### Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HFE26AA202 Damping Time 1.70 s  
Instrument Description MILL INLET AIR DAMPER Inspection Date 16-05-2024  
Manufacture AUMA  
Model SA162-F16  
Serial Number 2219MD24530  
Instrument Location BOILER 1.5TH FLOOR

### Environment Condition

Temperature 28.3 °C Traveling Time  
Humidity 43 % RH Open to Close 43.32 s  
Close to Open 44.61 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK  
Remark

### Test Equipment

Description Serial Number Certificate Number Calibration Date  
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 17-05-2024


Customer Signature,

  
Ayrton Humardani Putradhi

Approved Signatory

  
M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

  
Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

