

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0251-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HFE26CF002	Range	0 ~ 19.4
Instrument Description	PULVERIZER F PRIMARY AIR FLOW 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX130A / 91V501657	Max. Error	0.5 %
Instrument Location	BOILER 2ND FLOOR	Cal. Date	25-05-2026

Environment Condition

Temperature 23.9 °C Humidity 54 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	3.996	-0.004	-0.025	Pass						
4.900	8.041	8.056	0.015	0.094	Pass						
9.700	12.000	12.010	0.010	0.063	Pass						
14.700	16.123	16.178	0.055	0.344	Pass						
19.400	20.000	20.072	0.072	0.450	Pass						
14.700	16.123	16.176	0.053	0.331	Pass						
9.700	12.000	12.009	0.009	0.056	Pass						
4.900	8.041	8.054	0.013	0.081	Pass						
0.000	4.000	3.998	-0.002	-0.013	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒	Tightness Check ☒	Corrosion Check ☒
Accessories Check ☒	Power Supply ☒	

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 28-05-2026

Customer Signature,




Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Asriani

Calibrated by,



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person