

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0240-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE26CF003	Range	0 ~ 19.4
Instrument Description	PULVERIZER F PRIMARY AIR FLOW 3	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501658	Cal. Date	21-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature 27.3 °C
Humidity 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	4.003	0.003	0.019	Pass						
4.85	8.000	8.003	0.003	0.019	Pass						
9.70	12.000	11.997	-0.003	-0.019	Pass						
14.55	16.000	15.996	-0.004	-0.025	Pass						
19.40	20.000	19.993	-0.007	-0.044	Pass						
19.40	20.000	19.993	-0.007	-0.044	Pass						
14.55	16.000	16.000	0.000	0.000	Pass						
9.70	12.000	11.999	-0.001	-0.006	Pass						
4.85	8.000	7.993	-0.007	-0.044	Pass						
0.00	4.000	4.004	0.004	0.025	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module 700P23	20202302	S. 23 014 463	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 22-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Authorized by,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

