

REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 0990-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HFE35AA201 Sensitivity 0.5 %
 Instrument Description PULVERIZER E COLD PRIMARY AIR CONTROL DAMPER Damping Time 16.21 s
 Manufacture IMI CCI SMART POSITIONER Actuator Action ATO
 Model DU-60GHP/1003-E-S Inspection Date 16-05-2024
 Serial Number A24344JP-21E
 Instrument Location BOILER 1.5TH FLOOR

Environment Condition

Temperature 31.3 °C Humidity 43 % RH Traveling Time
 Open to Close 14.14 s Close to Open 16.33 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.1	19.990	100.0	0.0
25	25.4	15.850	74.8	22.5
50	50.5	11.920	49.7	45.0
75	75.3	7.910	24.5	67.5
100	99.8	4.010	0.1	90.0

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
 Corrosion Condition OK Not OK Accessories Check OK Not OK
 Air Regulator Check OK Not OK

Remark

Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 17-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signature,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person