

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0424-24-HI-CAL-10C

### Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

|                        |   |             |            |
|------------------------|---|-------------|------------|
| KKS No.                | 60HFE40CP001                            | Range       | -100 ~ 200 |
| Instrument Description | PULVERIZER D INLET PRIMARY AIR PRESSURE | Unit        | mbarg      |
| Manufacture            | YOKOGAWA                                | Out. Signal | 4 - 20 mA  |
| Model                  | EJX130A                                 | Max. Error  | 0.5 %      |
| Serial Number          | 91V501701                               | Cal. Date   | 24-05-2024 |
| Instrument Location    | BOILER 2ND FLOOR                        |             |            |

### Environment Condition

Temperature 27 °C  
Humidity 51 % RH

### Calibration Result

| Data Reading (Transmitter) |            |            |           |        |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |        |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbarg]                    | [mA]       | [mA]       |           | [%]    |        | [mbarg] | [mA]       | [mA]       |           | [%]   |        |
| -100                       | 4.000      | 4.001      | 0.001     | 0.006  | Pass   |         |            |            |           |       |        |
| -25                        | 8.000      | 8.003      | 0.003     | 0.019  | Pass   |         |            |            |           |       |        |
| 50                         | 12.000     | 12.001     | 0.001     | 0.006  | Pass   |         |            |            |           |       |        |
| 125                        | 16.000     | 16.004     | 0.004     | 0.025  | Pass   |         |            |            |           |       |        |
| 200                        | 20.000     | 20.004     | 0.004     | 0.025  | Pass   |         |            |            |           |       |        |
| 200                        | 20.000     | 20.004     | 0.004     | 0.025  | Pass   |         |            |            |           |       |        |
| 125                        | 16.000     | 16.002     | 0.002     | 0.012  | Pass   |         |            |            |           |       |        |
| 50                         | 12.000     | 12.002     | 0.002     | 0.013  | Pass   |         |            |            |           |       |        |
| -25                        | 8.000      | 8.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| -100                       | 4.000      | 3.997      | -0.003    | -0.019 | Pass   |         |            |            |           |       |        |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 56070038      | S. 22 002 081      | 17-02-2022       |
| Pressure Module Fluke 750PD4             | 4474073       | S. 23 014 461      | 10-10-2023       |

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page


Date of issue, 25-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

