

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0260-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE40CP004 Range -50 ~ 250
Instrument Description PULVERIZER D DIFFERENTIAL PRESSURE 3 Unit mbar
Manufacture YOKOGAWA Out. Signal 4 - 20 mA
Model / Serial Number EJX110A / 91V501625 Max. Error 0.5 %
Instrument Location BOILER 3RD FLOOR Cal. Date 26-05-2026

Environment Condition

Temperature 31 °C Humidity 72 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-50.000	4.000	4.004	0.004	0.025	Pass						
25.000	8.000	8.002	0.002	0.013	Pass						
100.000	12.000	12.003	0.003	0.019	Pass						
175.000	16.000	16.007	0.007	0.044	Pass						
250.000	20.000	20.007	0.007	0.044	Pass						
175.000	16.000	16.006	0.006	0.038	Pass						
100.000	12.000	12.002	0.002	0.013	Pass						
25.000	8.000	8.001	0.001	0.006	Pass						
-50.000	4.000	4.002	0.002	0.013	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

001 / Service-HI / 2022
Standard Operating Procedure of Pressure Transmitter Calibration

This certificate comprises 2 pages
Date of Issue, 02-06-2026

Customer Signature,

Erfan Nanda Gifari

Authorized Signature,

IVAN
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

