

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0425-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE50CP001	Range	-100 ~ 200
Instrument Description	PULVERIZER E INLET PRIMARY AIR PRESSURE	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501702	Cal. Date	24-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature: 27.3 °C
Humidity: 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	3.996	-0.004	-0.025	Pass						
-25	8.000	7.996	-0.004	-0.025	Pass						
50	12.000	11.996	-0.004	-0.025	Pass						
125	16.000	15.995	-0.005	-0.031	Pass						
200	20.000	20.004	0.004	0.025	Pass						
200	20.000	20.004	0.004	0.025	Pass						
125	16.000	16.006	0.006	0.038	Pass						
50	12.000	11.998	-0.002	-0.013	Pass						
-25	8.000	7.995	-0.005	-0.031	Pass						
-100	4.000	3.993	-0.007	-0.044	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 25-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

