

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0442-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFE60CP002	Range	-50 ~ 250
Instrument Description	PULVERIZER F DIFFERENTIAL PRESSURE 1	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501629	Cal. Date	25-05-2024
Instrument Location	BOILER 3RD FLOOR		

### Environment Condition

Temperature 27.3 °C  
 Humidity 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-50	4.000	3.996	-0.004	-0.025	Pass						
25	8.000	7.998	-0.002	-0.012	Pass						
100	12.000	11.999	-0.001	-0.006	Pass						
175	16.000	15.999	-0.001	-0.006	Pass						
250	20.000	20.004	0.004	0.025	Pass						
250	20.000	20.004	0.004	0.025	Pass						
175	16.000	16.003	0.003	0.019	Pass						
100	12.000	12.000	0.000	0.000	Pass						
25	8.000	7.999	-0.001	-0.006	Pass						
-50	4.000	3.998	-0.002	-0.012	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Taqif Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

