

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0444-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFE60CP004	Range	-50 ~ 250
Instrument Description	PULVERIZER F DIFFERENTIAL PRESSURE 3	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501631	Cal. Date	25-05-2024
Instrument Location	BOILER 3RD FLOOR		

### Environment Condition

Temperature 27.2 °C  
Humidity 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-50	4.000	4.001	0.001	0.006	Pass						
25	8.000	7.997	-0.003	-0.019	Pass						
100	12.000	11.999	-0.001	-0.006	Pass						
175	16.000	15.999	-0.001	-0.006	Pass						
250	20.000	20.005	0.005	0.031	Pass						
250	20.000	20.005	0.005	0.031	Pass						
175	16.000	16.001	0.001	0.006	Pass						
100	12.000	12.001	0.001	0.006	Pass						
25	8.000	8.000	0.000	0.000	Pass						
-50	4.000	4.002	0.002	0.012	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

