

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1007-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60HHE22AA202  
 Instrument Description: BURNER B2 COOLING AIR VALVE  
 Manufacture: HP SERIES  
 Model: APL-414N  
 Serial Number: DW1811320810031  
 Instrument Location: BOILER 3RD FLOOR

Damping Time: 0.5 s  
 Inspection Date: 25-05-2024

### Environment Condition

Temperature: 32 °C  
 Humidity: 44 % RH

Traveling Time  
 Open to Close: 4.52 s  
 Close to Open: 4.46 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
 Corrosion Condition:  OK  Not OK  
 Air Regulator Check:  OK  Not OK

Tightness Check:  OK  Not OK  
 Accessories Check:  OK  Not OK

### Remark

### Test Equipment

Description: STOPWATCH CASIO  
 Serial Number: J011Q03  
 Certificate Number: S. 23 004 599  
 Calibration Date: 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

