

## REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1013-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HHE25AA202 Damping Time 0.5 s  
 Instrument Description BURNER B5 COOLING AIR VALVE Inspection Date 25-05-2024  
 Manufacture HP-SERIES  
 Model APL-414N  
 Serial Number DW1811320810026  
 Instrument Location BOILER 3RD FLOOR

### Environment Condition

Temperature 32 °C  
 Humidity 43 % RH  
 Traveling Time  
 Open to Close 04.51 s  
 Close to Open 06.69 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK  
 Corrosion Condition  OK  Not OK  
 Air Regulator Check  OK  Not OK  
 Tightness Check  OK  Not OK  
 Accessories Check  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 26-05-2024


Customer Signature,

  
 Ayrton Humardani Putradhi

Approved Signatory,

  
 M. Tawfic Nur Fitriyan  
 INDONESIA

Calibrated by,

  
 Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

