

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1025-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60HHE35AA202  
Instrument Description: BURNER C5 COOLING AIR VALVE  
Manufacture: HKC  
Model: HG0-010  
Serial Number: DW1811320810026  
Instrument Location: BOILER 4TH FLOOR  
Damping Time: 1 s  
Inspection Date: 26-05-2024

### Environment Condition

Temperature: 29.5 °C  
Humidity: 44 % RH

### Traveling Time

Open to Close: 05.91 s  
Close to Open: 06.70 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
Corrosion Condition:  OK  Not OK  
Air Regulator Check:  OK  Not OK  
Tightness Check:  OK  Not OK  
Accessories Check:  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV


This certificate comprise of 1 page  
Date of issue, 27-05-2024

Customer Signature,



Ayrtun Humardani Putradhi


Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

