

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1033-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HHE43AA202	Damping Time	1 s
Instrument Description	BURNER D3 COOLING AIR VALVE	Inspection Date	24-05-2024
Manufacture	HKC		
Model	APL-414N		
Serial Number	DW1811300810041		
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature	28.7 °C	Traveling Time	
Humidity	54 % RH	Open to Close	06.05 s
		Close to Open	07.65 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK	Tightness Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK
Corrosion Condition	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK	Accessories Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK
Air Regulator Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK		

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 25-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person

