

REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1036-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

| | | | |
|------------------------|------------------------------|-----------------|------------|
| KKS No. | 60HHE45AA201 | Damping Time | 01.30 s |
| Instrument Description | PULVERIZER D OUTLET DAMPER 5 | Inspection Date | 28-05-2024 |
| Manufacture | KCC | | |
| Model | - | | |
| Serial Number | 23 | | |
| Instrument Location | BOILER 2ND FLOOR | | |

Environment Condition

Temperature 32 °C
Humidity 44 % RH

Traveling Time

Open to Close 03.01 s
Close to Open 04.02 s

Stroke Result

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

| | | | | | |
|---------------------|--|---------------------------------|-------------------|--|---------------------------------|
| Leak Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | Tightness Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK |
| Corrosion Condition | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | Accessories Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK |
| Air Regulator Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | | | |

Remark

Test Equipment

| Description | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 29-05-2024

Customer Signature,




Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

