

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1041-24-HI-CAL-10J

### Customer Information

Company Name PT. Bumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HHE51AA202 Damping Time 1 s  
 Instrument Description BURNER E1 COOLING AIR VALVE Inspection Date 26-05-2024  
 Manufacture HKC  
 Model HG0-050C  
 Serial Number DW1811320810040  
 Instrument Location BOILER 5TH FLOOR

### Environment Condition

Temperature 30.1 °C  
 Humidity 45 % RH

### Traveling Time

Open to Close 04.32 s  
 Close to Open 07.30 s

### Stroke Result

| Command | Feedback |       |      |       |
|---------|----------|-------|------|-------|
|         | Local    |       | DCS  |       |
|         | Open     | Close | Open | Close |
| Close   | -        | OK    | -    | OK    |
| Open    | OK       | -     | OK   | -     |

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Air Regulator Check  OK  Not OK

### Remark

### Test Equipment

| Description     | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03       | S. 23 004 599      | 27-03-2023       |

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 27-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person