

## REPORT OF INSPECTION

### ON-OFF VALVE

Certificate No. : 1042-24-HI-CAL-10J

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

#### Instrument Information

KKS No. 60HHE52AA201 Damping Time 01.30 s  
Instrument Description PULVERIZER E OUTLET DAMPER 2 Inspection Date 29-05-2024  
Manufacture KCC  
Model ACL  
Serial Number NCB160-3280Y-26  
Instrument Location BOILER 2ND FLOOR

#### Environment Condition

Temperature 31 °C  
Humidity 44 % RH

#### Traveling Time

Open to Close 03.57 s  
Close to Open 02.20 s

#### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

#### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

#### Remark

#### Test Equipment

Description Serial Number Certificate Number Calibration Date  
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

#### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 30-05-2024


Customer Signature,

  
Ayrton Humardani Putradhi

Approved Signatory,

  
M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

  
Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

