

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1043-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HHE52AA202 Damping Time 1 s  
 Instrument Description BURNER E2 COOLING AIR VALVE Inspection Date 26-05-2024  
 Manufacture HKC  
 Model HG0-050C  
 Serial Number DW1811320810036  
 Instrument Location BOILER 5TH FLOOR

### Environment Condition

Temperature 30.1 °C Traveling Time  
 Humidity 46 % RH Open to Close 05.41 s  
 Close to Open 08.95 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Air Regulator Check  OK  Not OK  
 Remark

### Test Equipment


Description Serial Number Certificate Number Calibration Date  
 STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 27-05-2024


Customer Signature,

  
 Ayrton Humardani Putradhi

Approved Signatory,

  
 M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,

  
 Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person