

## REPORT OF INSPECTION

### ON-OFF VALVE

Certificate No. : 1048-24-HI-CAL-10J

#### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

#### Instrument Information

KKS No.	60HHE55AA201	Damping Time	01.30 s
Instrument Description	PULVERIZER E OUTLET DAMPER 5	Inspection Date	29-05-2024
Manufacture	KCC		
Model	ACL		
Serial Number	NCB160-3280Y-29		
Instrument Location	BOILER 2ND FLOOR		

#### Environment Condition

Temperature	31 °C	Traveling Time	
Humidity	44 % RH	Open to Close	03.57 s
		Close to Open	02.20 s

#### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

#### Visual Inspection

Leak Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Tightness Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Corrosion Condition	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Accessories Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Air Regulator Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK			

#### Remark

#### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

#### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page

Date of issue, 30-05-2024


Customer Signature,

  
Ayrtun Humardani Putradhi

Approved Signatory,

  
M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

  
Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

