

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1050-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HHE56AA201 Damping Time 01:30 s  
 Instrument Description PULVERIZER E OUTLET DAMPER 6 Inspection Date 29-05-2024  
 Manufacture KCC  
 Model ACL  
 Serial Number NCB160-3280Y-30  
 Instrument Location BOILER 2ND FLOOR

### Environment Condition

Temperature 31 °C  
 Humidity 44 % RH  
 Traveling Time  
 Open to Close 03.57 s  
 Close to Open 02.20 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK  
 Corrosion Condition  OK  Not OK  
 Air Regulator Check  OK  Not OK  
 Remark  
 Tightness Check  OK  Not OK  
 Accessories Check  OK  Not OK

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 30-05-2024


Customer Signature,

  
 Ayrton Humardani Putradhi

Approved Signatory,

  
 M. Taqib Nur Fitriyan  
 INDONESIA

Calibrated by,

  
 Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person