

REPORT OF INSPECTION

ON-OFF VALVE

Certificate No. : 1058-24-HI-CAL-10J

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HHE64AA201 Damping Time 1.30 s
Instrument Description PULVERIZER F OUTLET DAMPER 4 Inspection Date 30-05-2024
Manufacture KCC
Model ACL
Serial Number NBC160-3208Y-34
Instrument Location BOILER 2nd FLOOR

Environment Condition

Temperature 30 °C Traveling Time
Humidity 44 % RH Open to Close 1.91 s
Close to Open 1.84 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 31-05-2024


Customer Signature,


Ayrtan Humardani Putradhi

Approved Signatory,


M. Taufiq Nur Fitriyan

Calibrated by,


Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

