

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0249-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HHF32CP002	Range	0 ~ 50
Instrument Description	WARMUP BURNER OIL PRESSURE 1	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501714	Cal. Date	19-05-2024
Instrument Location	BOILER 3RD FLOOR		

### Environment Condition

Temperature 31.2 °C  
 Humidity 60 % RH

### Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
12.500	8.000	7.994	-0.006	-0.038	Pass						
25.000	12.000	11.996	-0.004	-0.025	Pass						
37.501	16.001	15.996	-0.005	-0.031	Pass						
50.001	20.001	19.997	-0.004	-0.025	Pass						
50.001	20.001	19.997	-0.004	-0.025	Pass						
37.501	16.001	15.999	-0.002	-0.013	Pass						
25.000	12.000	11.997	-0.003	-0.019	Pass						
12.500	8.000	7.998	-0.002	-0.012	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Callibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 20-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

