

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0251-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HHF32CP004	Range	0 ~ 50
Instrument Description	WARMUP BURNER OIL PRESSURE 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501716	Cal. Date	19-05-2024
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature 31.2 °C
 Humidity 60 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
12.500	8.000	7.992	-0.008	-0.050	Pass						
25.000	12.000	11.989	-0.011	-0.069	Pass						
37.501	16.001	15.995	-0.006	-0.038	Pass						
50.001	20.001	19.990	-0.011	-0.069	Pass						
50.001	20.001	19.990	-0.011	-0.069	Pass						
37.501	16.001	15.992	-0.009	-0.056	Pass						
25.000	12.000	11.988	-0.012	-0.075	Pass						
12.500	8.000	7.993	-0.007	-0.044	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 700P08	14070183	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 20-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Yudianto Nur Fitriyani
 INDONESIA

Calibrated by,



Fandi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

