

## REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1068-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60HHF35AA222  
 Instrument Description: WARM UP OIL BURNER C1/C2 TIMING VALVE  
 Manufacture: HKC  
 Model: HG0-010  
 Serial Number: DW1811300910021  
 Instrument Location: BOILER 4TH FLOOR

Damping Time: 1 s  
 Inspection Date: 26-05-2024

### Environment Condition

Temperature: 29.5 °C  
 Humidity: 44 % RH

### Traveling Time

Open to Close: 0.89 s  
 Close to Open: 04.41 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
 Corrosion Condition:  OK  Not OK  
 Air Regulator Check:  OK  Not OK  
 Tightness Check:  OK  Not OK  
 Accessories Check:  OK  Not OK

### Test Equipment

Description: STOPWATCH CASIO  
 Serial Number: J011Q03  
 Certificate Number: S. 23 004 599  
 Calibration Date: 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 27-05-2024

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,

M. Taufiq Nurfitriyan

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person