

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1078-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HHF38AA231 Damping Time 1 s
 Instrument Description WARM UP OIL BURNER F3/F4 INLET SHUT OFF VALVE Inspection Date 25-05-2024
 Manufacture HP-SERIES
 Model HG0-050C
 Serial Number DW1904100111024
 Instrument Location BOILER 3.5TH FLOOR

Environment Condition

Temperature 30 °C
 Humidity 42 % RH
 Traveling Time
 Open to Close 01.32 s
 Close to Open 04.40 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK
 Corrosion Condition OK Not OK
 Air Regulator Check OK Not OK
 Tightness Check OK Not OK
 Accessories Check OK Not OK

Remark

Test Equipment

Description STOPWATCH CASIO Serial Number J011Q03 Certificate Number S. 23 004 599 Calibration Date 27-03-2023

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 26-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Tauliq Nur Fitriyan

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person