

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1081-24-HI-CAL-10J

### Customer Information

Company Name  
Address  
Contract No.

PT. Bhumi Jati Power  
PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
C-BJP-24-0014-OTH

### Instrument Information

KKS No.  
Instrument Description  
Manufacture  
Model  
Serial Number  
Instrument Location

60HHF38AA252  
WARM UP OIL BURNER F5/F6 TIMING VALVE  
HP-SERIES  
HGO-010  
DW1811300910026  
BOILER 3.5TH FLOOR

Damping Time 0.5 s  
Inspection Date 25-05-2024

### Environment Condition

Temperature  
Humidity

30 °C  
42 % RH

### Traveling Time

Open to Close 02.00 s  
Close to Open 04.88 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  
Corrosion Condition  
Air Regulator Check  
Remark

OK  Not OK  
 OK  Not OK  
 OK  Not OK

Tightness Check  OK  Not OK  
Accessories Check  OK  Not OK

### Test Equipment

Description  
STOPWATCH CASIO

Serial Number  
J011Q03

Certificate Number  
S. 23 004 599

Calibration Date  
27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Dayday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

