

## REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 1082-24-HI-CAL-10J

### Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HJF32AA201 Sensitivity 0.5 %  
Instrument Description IGNITION LIGHT OIL PRESSURE CONTROL VALVE Damping Time 0.5 s  
Manufacture FISHER Actuator Action ATC  
Model EZ-667 Inspection Date 06-06-2024  
Serial Number J220973  
Instrument Location Boiler Lt. 3

### Environment Condition

Temperature 30.1 °C Humidity 44 % RH  
Traveling Time  
Open to Close 1.38 s Close to Open 2.03 s

### Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]
0	0.1	3.980	0.0	0
25	25.4	8.060	25.0	4.75
50	50.4	12.090	50.3	9.5
75	75.4	16.060	75.5	14.25
100	99.8	19.800	100.0	19

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[mm]

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
AMS Trex Device Communicator	230200023794	-	16-05-2024
FIK-87-V MULTIMETER	45910296	S. 22 008 273	13-07-2022

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page

Date of issue, 07-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

