

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1097-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HJF35AA212	Damping Time	1 s
Instrument Description	OIL IGNITER C1/C2 INLET SHUT OFF VALVE 2	Inspection Date	26-05-2024
Manufacture	HKC		
Model	HG0-050C		
Serial Number	DW1811300908070		
Instrument Location	BOILER 4TH FLOOR		

Environment Condition

Temperature 29.5 °C
Humidity 44 % RH

Traveling Time

Open to Close 01.32 s
Close to Open 05.28 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Tightness Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Corrosion Condition	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK	Accessories Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK
Air Regulator Check	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> Not OK			

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 27-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Tawfik Nur Fitriyan
INDONESIA

Calibrated by,



Daday Daryalun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

