

REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1104-24-HI-CAL-10J

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HJF36AA231	Damping Time	0.5 s
Instrument Description	OIL IGNITER D3/D4 INLET SHUT OFF VALVE 1	Inspection Date	24-05-2024
Manufacture	SP-SERIES		
Model	HG0-010		
Serial Number	DW1811300908032		
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature: 28.7 °C
Humidity: 54 % RH

Traveling Time

Open to Close: 01.02 s
Close to Open: 05.89 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check: OK Not OK
Corrosion Condition: OK Not OK
Air Regulator Check: OK Not OK

Tightness Check: OK Not OK
Accessories Check: OK Not OK

Remark

Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 25-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fityan
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

