

## REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1105-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60HJF36AA232  
 Instrument Description: OIL IGNITER D3/D4 INLET SHUT OFF VALVE 2  
 Manufacture: HP-SERIES  
 Model: HG0-010  
 Serial Number: DW19041009013  
 Instrument Location: BOILER 3RD FLOOR  
 Damping Time: 1 s  
 Inspection Date: 24-05-2024

### Environment Condition

Temperature: 28.7 °C  
 Humidity: 54 % RH  
 Traveling Time  
 Open to Close: 01.02 s  
 Close to Open: 05.89 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
 Corrosion Condition:  OK  Not OK  
 Air Regulator Check:  OK  Not OK  
 Tightness Check:  OK  Not OK  
 Accessories Check:  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 25-05-2024

Customer Signature,

  
 Ayrtan Humardani Putradhi

Approved Signature,

  
 M. Taufiq Nur Fityan  
 INDONESIA

Calibrated by,

  
 Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person

