

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1117-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HJF38AA232 Damping Time 1 s
 Instrument Description OIL IGNITER F3/F4 INLET SHUT OFF VALVE 2 Inspection Date 25-05-2024
 Manufacture HP-SERIES
 Model HGO-010
 Serial Number DW1811300908053
 Instrument Location BOILER 3.5TH FLOOR

Environment Condition

Temperature 30 °C Traveling Time
 Humidity 42 % RH Open to Close 01.75 s
 Close to Open 05.51 s

Stroke Result

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
 Corrosion Condition OK Not OK Accessories Check OK Not OK
 Air Regulator Check OK Not OK
 Remark

Test Equipment

Description Serial Number Certificate Number Calibration Date
 STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 26-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Fauzi Nur Fitriyan
 INDONESIA

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person