

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1119-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HJF38AA252 Damping Time 1 s  
 Instrument Description OIL IGNITER F5/F6 INLET SHUT OFF VALVE 2 Inspection Date 25-05-2024  
 Manufacture HP-SERIES  
 Model HG0-010  
 Serial Number DW1811300908028  
 Instrument Location BOILER 3.5TH FLOOR

### Environment Condition

Temperature 30 °C Traveling Time  
 Humidity 42 % RH Open to Close 01.45 s  
 Close to Open 04.79 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Air Regulator Check  OK  Not OK  
 Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 26-05-2024

Customer Signature,



Ayron Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
 This certificate applies only for the item specified above  
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
 \*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
 This certificate is valid if it has approved and signed by authorized person