

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0258-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HJN00CP003	Range	0 ~ 15
Instrument Description	BURNER ATOMIZING AIR PRESSURE 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0,5 %
Serial Number	91V501729	Cal. Date	21-05-2024
Instrument Location	BOILER 2ND FLOOR		

### Environment Condition

Temperature 32 °C  
Humidity 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
3.75	8.000	8.002	0.002	0.013	Pass						
7.50	12.000	12.001	0.001	0.006	Pass						
11.25	16.000	16.003	0.003	0.019	Pass						
15.00	20.000	20.004	0.004	0.025	Pass						
15.00	20.000	20.004	0.004	0.025	Pass						
11.25	16.000	16.000	0.000	0.000	Pass						
7.50	12.000	12.004	0.004	0.025	Pass						
3.75	8.000	8.003	0.003	0.019	Pass						
0.00	4.000	4.001	0.001	0.006	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 22-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

