

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1121-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HJN11AA212	Damping Time	0.5 s
Instrument Description	OIL IGNITER A1/A2 PURGE VALVE	Inspection Date	25-05-2024
Manufacture	HKC		
Model	HG0-010		
Serial Number	DW1811300908060		
Instrument Location	BOILER 5TH FLOOR		

Environment Condition

Temperature	26.9 °C	Traveling Time	
Humidity	59 % RH	Open to Close	0.70 s
		Close to Open	01.91 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK	Tightness Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK
Corrosion Condition	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK	Accessories Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK
Air Regulator Check	<input checked="" type="checkbox"/> OK <input type="checkbox"/> Not OK		

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 26-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person