

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1127-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HJN21AA212
Instrument Description OIL IGNITER B1/B2 PURGE VALVE
Manufacture HP-SERIES
Model HG0-010
Serial Number DW1811300908073
Instrument Location BOILER 3RD FLOOR

Damping Time 1 s

Inspection Date 25-05-2024

Environment Condition

Temperature 32 °C

Humidity 43 % RH

Traveling Time

Open to Close 1.0 s

Close to Open 05.11 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check

OK Not OK

Corrosion Condition

OK Not OK

Air Regulator Check

OK Not OK

Tightness Check

OK Not OK

Accessories Check

OK Not OK

Remark

Test Equipment

Description
STOPWATCH CASIO

Serial Number
J011Q03

Certificate Number
S. 23 004 599

Calibration Date
27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

