

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1130-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0014-0TH

### Instrument Information

KKS No.: 60HJN21AA251  
Instrument Description: OIL IGNITER B5/B6 COOLING VALVE  
Manufacture: HP-SERIES  
Model: HG0-010  
Serial Number: DW1904100109053  
Instrument Location: BOILER 3RD FLOOR  
Damping Time: 1 s  
Inspection Date: 25-05-2024

### Environment Condition

Temperature: 33 °C  
Humidity: 44 % RH  
Traveling Time  
Open to Close: 0.52 s  
Close to Open: 5.06 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check:  OK  Not OK  
Corrosion Condition:  OK  Not OK  
Air Regulator Check:  OK  Not OK  
Tightness Check:  OK  Not OK  
Accessories Check:  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 26-05-2024


Customer Signature,

  
Ayrtan Humardani Putradhi

Approved Signature,

  
M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

  
Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

