

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1141-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HJN31AA232 Damping Time 1 s
Instrument Description OIL IGNITER C3/C4 PURGE VALVE Inspection Date 26-05-2024
Manufacture HKC
Model HG0-010
Serial Number DW1811300908071
Instrument Location BOILER 4TH FLOOR

Environment Condition

Temperature 30.1 °C
Humidity 45 % RH

Traveling Time

Open to Close 0.72 s
Close to Open 04.26 s

Stroke Result

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment

| Description | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV


This certificate comprise of 1 page
Date of issue, 27-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

