

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1143-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No.	60HJN31AA252	Damping Time	1 s
Instrument Description	OIL IGNITER C5/C6 PURGE VALVE	Inspection Date	26-05-2024
Manufacture	HKC		
Model	HG0-010		
Serial Number	DW1811300908072		
Instrument Location	BOILER 4TH FLOOR		

### Environment Condition

Temperature 29.5 °C  
Humidity 44 % RH

### Traveling Time

Open to Close 0.59 s  
Close to Open 04.34 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Air Regulator Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

### Remark

### Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 27-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

