

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1148-24-HI-CAL-10J

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0014-OTH

Instrument Information

KKS No.: 60HJN40AA251
 Instrument Description: WARM UP OIL BURNER D5/D6 ATOMIZING VALVE
 Manufacture: SP-SERIES
 Model: HG0-050C
 Serial Number: DW1811300909013
 Instrument Location: TURBINE 3RD FLOOR

Damping Time: 1 s
 Inspection Date: 24-05-2024

Environment Condition

Temperature: 28.7 °C
 Humidity: 54 % RH

Traveling Time
 Open to Close: 01.26 s
 Close to Open: 02.70 s

Stroke Result

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

Leak Check: OK Not OK
 Corrosion Condition: OK Not OK
 Air Regulator Check: OK Not OK

Tightness Check: OK Not OK
 Accessories Check: OK Not OK

Remark

Test Equipment

| Description | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 25-05-2024


Customer Signature,


 Ayrtan Humardani Putradhi

HERVITAMA
 Approved Signatory,


 M. Fauzi Nur Fitriyan
 INDONESIA

Calibrated by,


 Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

