

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1154-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0014-OTH

Instrument Information

| | | | |
|------------------------|---------------------------------|-----------------|------------|
| KKS No. | 60HJN41AA251 | Damping Time | 0.5 s |
| Instrument Description | OIL IGNITER D5/D6 COOLING VALVE | Inspection Date | 24-05-2024 |
| Manufacture | HP-SERIES | | |
| Model | HG0-010 | | |
| Serial Number | DW1811300908025 | | |
| Instrument Location | BOILER 3RD FLOOR | | |

Environment Condition

| | | | |
|-------------|---------|----------------|---------|
| Temperature | 28.7 °C | Traveling Time | |
| Humidity | 54 % RH | Open to Close | 01.64 s |
| | | Close to Open | 05.19 s |

Stroke Result

| Command | Feedback | | | |
|---------|----------|-------|------|-------|
| | Local | | DCS | |
| | Open | Close | Open | Close |
| Close | - | OK | - | OK |
| Open | OK | - | OK | - |

Visual Inspection

| | | | | | |
|---------------------|--|---------------------------------|-------------------|--|---------------------------------|
| Leak Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | Tightness Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK |
| Corrosion Condition | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | Accessories Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK |
| Air Regulator Check | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> Not OK | | | |

Remark

Test Equipment

| Description | Serial Number | Certificate Number | Calibration Date |
|-----------------|---------------|--------------------|------------------|
| STOPWATCH CASIO | J011Q03 | S. 23 004 599 | 27-03-2023 |

Inspection Method

0007/SOP_BJS/2023
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
 Date of issue, 25-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA
 Approved Signatory,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

