

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1161-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HJN51AA252 Damping Time 1 s  
Instrument Description OIL IGNITER E5/E6 PURGE VALVE Inspection Date 26-05-2024  
Manufacture HKC  
Model HG0-010  
Serial Number DW181130098039  
Instrument Location BOILER 5TH FLOOR

### Environment Condition

Temperature 30.1 °C  
Humidity 45 % RH

### Traveling Time

Open to Close 0.78 s  
Close to Open 0.431 s

### Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Air Regulator Check  OK  Not OK

### Remark

### Test Equipment


Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 27-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Authorized Signatory,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

