

REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 1164-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HJN60AA231 Damping Time 1 s
Instrument Description WARM UP OIL BURNER F3/F4 ATOMIZING VALVE Inspection Date 25-05-2024
Manufacture HP-SERIES
Model HG0-050C
Serial Number DW1811300909004
Instrument Location BOILER 3.5TH FLOOR

Environment Condition

Temperature 32 °C
Humidity 44 % RH

Traveling Time

Open to Close 01.00 s
Close to Open 05.88 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S, 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 26-05-2024


Customer Signature,


Ayrton Humardani Putradhi

Approved Signatory


M. Taufiq Nur Fitriyan
INDONESIA

Calibrated by,


Daday Daryatur

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person