

REPORT OF INSPECTION ON-OFF VALVE Certificate No. : 1172-24-HI-CAL-10J

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0014-OTH

Instrument Information

KKS No.: 60HJN61AA251 Damping Time: 1 s
Instrument Description: OIL IGNITER F5/F6 COOLING VALVE Inspection Date: 25-05-2024
Manufacture: HP-SERIES
Model: HG0-010
Serial Number: DW1811300908035
Instrument Location: BOILER 3.5TH FLOOR

Environment Condition

Temperature: 32 °C Traveling Time
Humidity: 44 % RH Open to Close: 01.00 s
Close to Open: 04.63 s

Stroke Result

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check: OK Not OK Tightness Check: OK Not OK
Corrosion Condition: OK Not OK Accessories Check: OK Not OK
Air Regulator Check: OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved by,



M. Tawin Nur Fidiyan
INDONESIA

Calibrated by,



Dayad Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

